

In progress

To be implemented

- Utilizing local radio stations, deploying PR vehicles, etc.
- Reports on failures of reactor facilities and accidents related to electricity(Final report relating to the causes and measures) (Sep. 25)
 - Causes and measures related to the water from the spent fuel pool to flood over and ending outside
 - Causes and measures related to damage to R/B overhead crane drive axle joint of Unit 6
 - Causes and measures related to the fire in the duct of Unit 3 house transformer (B)